Uncertainty propagation in model extraction by system identification and its implication on control design

NICOLAS DOVETTA^{1†},
PETER J. SCHMID² AND DENIS SIPP³

¹Saint Gobain Research, Process Modeling Group, F-93303 Aubervilliers, France

²Department of Mathematics, Imperial College London, London SW7 2AZ, United Kingdom

³ONERA-DAFE, 8 rue des Vertugadins, F-92190 Meudon, France

(Received ?; revised ?; accepted ?. - To be entered by editorial office)

In data-based control design, system-identification techniques are used to extract low-dimensional representations of the input-output map between actuators and sensors from observed data-signals. Under realistic conditions, noise in the signals is present and is expected to influence the identified system representation. For the subsequent design of the controller, it is important to gauge the sensitivity of the system representation to noise in the observed data; this information will impact the robustness of the controller and influence the stability margins for a closed-loop configuration. Commonly, Monte-Carlo analysis has been used to quantify the effect of data-noise on the system identification and control design, but in fluid systems, this approach is often prohibitively expensive, both for numerical simulations and physical experiments. Instead, we present a framework for the estimation of statistical properties of identified system representations given an uncertainty in the processed data. The ARMarkov/LS identification procedure has been chosen to illustrate this framework and to obtain error bounds on the identified system parameters based on the signal-to-noise ratio of the input-output data sequence. Multiple simulations (as in Monte-Carlo techniques) are not necessary, which makes the proposed technique affordable and efficient even for large-scale flow control problems. The procedure is illustrated on the control design for flow over an idealized airfoil with a trailing-edge splitter plate.

Key words: uncertainty, ARMarkov model, system identification, flow control, sensitivity analysis

1. Introduction

Flow control is an attractive and promising technology as it aims at altering and improving inherent flow behavior by externally applied forces. Reducing drag, suppressing instabilities, extending parameter envelopes or enhancing mixing are only a few objectives that could be accomplished by flow control strategies. Despite its potential for technological advances, the design of flow control schemes still poses significant challenges, principally among them the modelling of the flow behavior and the accurate description of the disturbance environment.

† Email address for correspondence: nicolas.dovetta@saint-gobain.com

Model-based approaches, based on a prescribed set of equations and an *a priori* assumption on the characteristics of the noise environment, have been successfully applied to numerical simulations and have demonstrated their effectiveness within the range of design assumptions. For applications in experiments, in the absence of sufficient information on the disturbance environment, a different approach may be more appropriate that does not impose a preconceived model but rather extracts information for the control design, such as transfer functions, directly from measured (noise-contaminated) data. Techniques in this category rely on system identification methods to obtain representations of the flow's input-output behavior; they fall into two major families: subspace identification and Markov-parameter/realization techniques. Whereas the former exploits the low-rank nature of the control signal space to arrive at approximate system matrices via oblique projections (see, e.g., Katayama 2005), the latter first determines the discrete impulse responses (Markov parameters) of the flow which are then, in a second step, used to derive a state-space model.

System identification has been an active field of research for many decades and has matured into a well-established discipline of system theory. Even though many techniques and algorithms are available, the use of system-identification techniques in the design of flow control strategies is rather recent (see Kim 2003; Hervé *et al.* 2012; Juillet *et al.* 2013). For the identification of a reduced-order model that will form the basis of our control design, a two-step process, referred to as the separation principle, is often advocated (see, e.g., Hjalmarsson 2005). It consists of a high-order identification of a preliminary model that best fits the available data, which is subsequently transformed into a low-order representation by model-reduction techniques. The two-step approach ensures favorable statistical properties, since the asymptotic efficiency of the high-order system can be shown to be inherited by the low-order system; furthermore, the thus reduced low-order system is optimal within the constraints given by the high-order system.

Following this separation principle, we choose a Markov parameter/realization technique in this study. In particular, we use a ARMarkov/LS technique to convert measured data-sequences into discrete impulse responses (Markov parameters) by assuming an underlying auto-regressive model that explicitly contains the Markov parameters; the parameters of the auto-regressive model are determined by a least-squares (LS) matching to the measured data. The Markov parameters are then used in the Eigensystem Realization Algorithm (ERA) to arrive at a state-space representation of the model, which in turn can be used to design a control law by standard techniques. The ARMarkov/LS procedure has originally been proposed by Akers & Bernstein (1997), and many subsequent studies (see Van Pelt & Bernstein 1998; Kamrunnagar *et al.* 2000; Fledderjohn *et al.* 2010) have confirmed it as a very efficient technique to obtain the Markov parameters of a system. The ERA state-space realization step has been developed by Juang & Pappa (1985), has been studied extensively (see Lew *et al.* 1993) and has recently been applied to flow control problems in the form of an adjoint-free model reduction procedure (see Ma *et al.* 2011).

One of the advantages and appeal of data-based control design using system identification techniques are its applicability to realistic flow situations, where the only information about the system to be controlled consists of (low-dimensional) measurements. This advantage is, however, off-set by the uncertainty these signals introduce into the design process, since the processed data will surely be contaminated by background and measurement noise and ultimately affect the control performance. In particular, for a practical control design, it is important to quantify the noise in the data and how it propagates through the procedural steps of the system identification and control design to ultimately influence the control performance and its internal stability margins. A sen-

sitivity analysis of this type is the focus of this article. Due to the separation principle, we can break apart the error in the identification step into a variance estimation of the identified model and a bias estimation of the reduced-order model. This distinction is valid as long as the model reduction step is robust, i.e., shows a negligible sensitivity of the model parameters to noise in the underlying data.

Computing estimates of the variance and bias error with respect to variations in the model parameters for an identification-realization algorithm has been the topic of previous articles in the identification/realization literature. For example, the model-order criteria of Akaike (1974) and Rissanen (1983) apply penalization techniques to a repeatability estimate to arrive at an objective model order (see Ljung 1987). In the study of Longman *et al.* (1991), the model parameters for the ERA-step have been chosen based on statistical information of the identified variables. Besides its obvious benefits for control and stability calculations, the quantification of the variance and bias of the identification-realization parameters can also be used as a model structure falsification criterion (see Hjalmarsson 2005).

This paper is concerned with the propagation of uncertainties and stochastic fluctuations in the processed data through a multi-step procedure based on system identification, state-space realization and optimal control design. In particular, we wish to quantify how small perturbations in the data will ultimately affect closed-loop control performance and degrade internal stability margins. We start in section § 2 by presenting the ARMarkov/LS/ERA identification-realization algorithm for a single-input single-output (SISO) system. Section § 3 will then concentrate on a perturbation technique to derive estimates of the error between the real and identified model; this section naturally divides into two parts: quantifying the ARMarkov/LS-identification error and deriving an ERA error estimate. A validation of these error estimates is presented in section § 4, where we consider a one-dimensional (thus computationally tractable) model problem that mimics noise-amplifier flows. Numerical simulations of flow over a backward-facing step will be used to illustrate the introduced techniques on a more realistic flow configuration and to demonstrate the utility of sensitivity measures in the analysis of closed-loop control problems based on system identification and realization. Conclusions are presented in § 5.

2. From data-sequences to control performance

We start by developing the essential steps in the design of an efficient and robust control strategy, starting from input-output data sequences. These steps will consist of (i) a system identification process, which matches the coefficients of a given model structure using observed input-output signals, (ii) a design of a feedback or feed-forward controller, and (iii) the assessment of gain and phase margins of the compensated system.

2.1. General framework for linear time-invariant systems (LTI)

We choose a discrete-time state-space representation to describe the flow-control setup for a linear time-invariant (LTI) system and consider a single input and single output (i.e., a SISO-system). We have

$$\mathbf{x}(k+1) = \mathbf{A}\mathbf{x}(k) + \mathbf{B}u(k) + \mathbf{E}_x w_x(k), \quad (2.1a)$$

$$y(k) = \mathbf{C}\mathbf{x}(k) + \mathbf{D}u(k) + \mathbf{E}_y w_y(k), \quad (2.1b)$$

where k denotes the discrete time index, $\mathbf{x}(k)$ represents the state vector, $u(k)$ is the control, $y(k)$ stands for the measurement, and $w_x(k)$ and $w_y(k)$ are the state noise and

measurement uncertainties, respectively. The system matrix is given by $\mathbf{A}$, the actuation is modeled by $\mathbf{B}$, and the sensors by $\mathbf{C}$. The spatial distribution of the noise is contained in the matrices $\mathbf{E}_x$ and $\mathbf{E}_y$, for the state vector and measurements, respectively. Finally, $\mathbf{D}$ describes the instantaneous effect of the actuation on the measurement. For a system of order n , the system matrix $\mathbf{A}$ is $n \times n$, the actuation matrix $\mathbf{B}$ is $n \times 1$, the sensor matrix $\mathbf{C}$ is $1 \times n$, and $\mathbf{D}$ is a scalar. Finally, $\mathbf{E}_x, \mathbf{E}_y, \mathbf{w}_x$ and $\mathbf{w}_y$ are matrices and vectors of dimensions that correspond to the order of the noise.

The impulse response of the above system (2.1), in the case of vanishing noise matrices, can be defined as a sequence of scalars. This sequence is also referred to as the Markov parameters $\mathbf{H}_j$. From the state-space representation (2.1) an explicit form of the Markov parameters can be derived according to

$$\mathbf{H}_0 = \mathbf{D}, \quad (2.2a)$$

$$\mathbf{H}_j = \mathbf{C}\mathbf{A}^{j-1}\mathbf{B}, \quad j \geq 1. \quad (2.2b)$$

Based on these Markov parameters, we can formulate regressive or auto-regressive representations of the system's input-output behavior that do not involve the state-vector $\mathbf{x}(k)$. Rather, the output at k can be determined solely as functions of past inputs and outputs. The definition (2.2) of the Markov parameters $\mathbf{H}_j$ then allows us to formulate a regressive representation of general LTI-systems as a discrete transfer function from the input u to the output y . We obtain

$$y(k) = \sum_{j=0}^{\infty} \mathbf{H}_j u(k-j). \quad (2.3)$$

An approximation of this model, assuming that after a certain time the effects of the actuations are negligible, is the well-known Finite Impulse Response (FIR) model of order μ . We have

$$y(k) = \sum_{j=0}^{\mu-1} \mathbf{H}_j u(k-j). \quad (2.4)$$

A more sophisticated representation is applying an auto-regressive term to the signal y which yields the well-known ARX (auto-regressive-exogenous-input) model

$$y(k) = \sum_{j=1}^n -\mathbf{N}_j y(k-j) + \sum_{j=0}^n \mathbf{M}_j u(k-j) \quad (2.5)$$

where $\mathbf{M}_j$ and $\mathbf{N}_j$ are coefficients to be determined. Akers & Bernstein (1997) showed that the Markov parameters can be extracted from the ARX representation via the following recursive algorithm. Using (2.5) and the definition of the measurement y we obtain, after repeated substitution, the following auto-regressive representation that explicitly isolates μ Markov parameters (referred to as μ -ARMarkov):

$$y(k) = \sum_{j=1}^n -\mathbf{P}_j y(k-\mu-j+1) + \sum_{j=1}^{\mu} \mathbf{H}_{j-1} u(k-j+1) + \sum_{j=1}^n \mathbf{Q}_j u(k-\mu-j+1). \quad (2.6)$$

To proceed, the μ -ARMarkov model may be written as a linear relation between $y(k)$, a vector $\phi(k)$ and the model parameters, grouped into the vector $\mathbf{W}$, according to

$$y(k) = \phi(k)\mathbf{W}, \quad (2.7)$$

where $\phi(k)$ and $\mathbf{W}$ are given as

$$\phi(k) = [y(k - \mu), \dots, y(k - \mu - n + 1), u(k), \dots, u(k - \mu - n + 1)], \quad (2.8)$$

and

$$\mathbf{W}^T = [-\mathbf{P}_1, \dots, -\mathbf{P}_n, \mathbf{H}_0, \dots, \mathbf{H}_{\mu-1}, \mathbf{Q}_1, \dots, \mathbf{Q}_n]. \quad (2.9)$$

Equation (2.7) is a compact form of the auto-regressive representation of equation (2.6) where $\phi(k)$ contains the input-output sequence just before the k^{th} time index and $\mathbf{W}$ contains the ARMarkov parameters. The transfer functions based on the z -transform of the above models (FIR, ARMA and μ -ARMarkov) are given in the appendix for completeness. The following section presents the algorithm proposed by Akers & Bernstein (1997) to identify the μ -ARMarkov parameters (in $\mathbf{W}$) from input-output data sequences. Once the Markov parameters are identified (as a part of the vector $\mathbf{W}$), the system behavior is predicted using the FIR model (2.4). The other coefficients (*i.e.* $\mathbf{P}_i$ and $\mathbf{Q}_i$) — even though ultimately not used — are to account for noise in the data-set and thus yield more accurate Markov parameters (see Hjalmarsson 2005; Kamrunnahr *et al.* 2000).

2.2. From data to an identified system: ARMarkov/Least Squares

This section shows how the coefficients of the ARMarkov model are obtained from data-sequences via a least-squares minimization. Many alternative techniques exist to identify model coefficients, in particular, for the ARMarkov representation. While details are kept to a minimum in what follows, the interested reader is referred to Ljung (1987); Hjalmarsson (2005) for more information about the mathematical and algorithmic principles underlying system identification.

2.2.1. The Least-Squares (LS) algorithm

Given an input-output data-set, a system identification procedure is concerned with finding a model that can reproduce the output (y) sequence using the input (u) sequence. Formally, $y(k)$ is the array of measured outputs at time k , $\mathbf{W}$ denotes a set of parameters that describe the model, and $\hat{y}(k|\mathbf{W})$ stands for the output computed using the input sequence and the model parameterized by $\mathbf{W}$. The goal is to find $\mathbf{W}$ such that the sequence $\hat{y}(k|\mathbf{W})$ best matches $y(k)$. Thus, the ARMarkov/LS-identification consists of minimizing J given by

$$J(\mathbf{W}) = \frac{1}{N} \sum_{k=1}^N (y(k) - \hat{y}(k|\mathbf{W}))^2, \quad (2.10)$$

with N as the number of data points. For ARMarkov, the relationship between $\hat{y}(k|\mathbf{W})$ and $\mathbf{W}$ is explicit and given by (2.7). Substituting into (2.10) yields

$$J(\mathbf{W}) = \|\mathbf{Y} - \Phi\mathbf{W}\|_2^2 \quad (2.11)$$

with

$$\mathbf{Y} = \begin{pmatrix} y(\mu + n) \\ y(\mu + n + 1) \\ \vdots \\ y(N) \end{pmatrix} \quad \text{and} \quad \Phi = \begin{pmatrix} \phi(\mu + n) \\ \phi(\mu + n + 1) \\ \vdots \\ \phi(N) \end{pmatrix}. \quad (2.12)$$

The minimization of $J(\mathbf{W})$ may be solved using the pseudo-inverse to obtain

$$\mathbf{W} = \Phi^\dagger \mathbf{Y}. \quad (2.13)$$

The coefficient vector $\mathbf{W}$ contains the Markov parameters $\mathbf{H}_j$. The pseudo-inverse is often computed using Moore's definition

$$\Phi^\dagger \equiv \lim_{\epsilon \rightarrow 0} (\Phi^T \Phi + \epsilon \mathbf{I})^{-1} \Phi^T \quad (2.14)$$

which minimizes a regularized cost functional $\tilde{J}(\mathbf{W})$ of the form

$$\tilde{J}(\mathbf{W}) = \lim_{\epsilon \rightarrow 0} \|\mathbf{Y} - \Phi \mathbf{W}\|_2^2 + \epsilon \|\mathbf{W}\|_2^2 \quad (2.15)$$

The parameter ϵ can be set to machine precision, but it can also be used to enforce regularization of an otherwise ill-posed problem, as Φ is often rank-deficient. Φ contains the input-output data-sequence: when the input does not consist of a broad-band signal, the resulting least-squares problem becomes ill-posed. In this case, the use of Moore's pseudo-inverse definition allows us to implement a Tikhonov regularization of the problem ($\epsilon \neq 0$, Fleming (2011)). This way, the norm of $\mathbf{W}$ remains bounded which, in turn, avoids numerical problems when using the identified model. In the different test cases presented in this paper, regularization is always applied with ϵ ranging from 10^{-5} to 10^{-16} (machine precision). The choice of ϵ depends on the application and the ill-posedness of the data-sequence (Φ).

In order to have $\mathbf{W}$ represent the system's dynamics rather than measurement noise, the minimization problem should be strongly under-parametrized, i.e., $2n + \mu \ll N$. In the limiting case of $2n + \mu = N$, the input-output data sequence (u, y) will be exactly matched by the reconstructed data $(u, \hat{y})$. In this case, the model parameters in $\mathbf{W}$ are strongly noise-dependent and will unlikely be consistent with another set of data. In our examples, the parameters are chosen such that $2n + \mu < N/5$; this choice is related to the AIC criterion defined below (see equation (2.16)). Even so, the model parameters in $\mathbf{W}$ are still dependent on noise, where the majority of this dependence is contained in the auto-regressive part of $\mathbf{W}$. For this reason, only the Markov parameters are kept (see Hjalmarsson 2005; Kamrunnagar *et al.* 2000), to minimize the noise dependence. The ARMarkov/LS procedure identifies all coefficients of the ARMarkov representation, but only a finite impulse response (FIR, i.e., the set of Markov parameters) transfer function is kept. Still, with all these precautions to identify a model that faithfully represents the system dynamics, the Markov parameters are influenced by noise, especially in realistic data-set where the noise-to-signal ratio may be rather high. The uncertainty propagation analysis aims at quantitatively estimating this dependence in order to improve the prediction of a controller's performance.

2.2.2. Choice of data sequence

As we saw, the choice of the spectral content of the inputs has a significant impact on the statistical property of the identified model, as it is related to the well-posedness of the minimization problem. For the examples given in this article the input will be chosen as a Pseudo-Random Binary Signal (PRBS): it is broad-band, widely used and actuator-friendly. For details on the choice and implications of the input signals, the reader is referred to the studies of Gerencser *et al.* (2009); Brighenti *et al.* (2009); Mehra (1974).

2.2.3. Model order and its link to model estimation error

The order of the model constitutes a crucial choice that has to be made in the identification process. For an ARMarkov model the order is $2n + \mu$, while for a FIR model the order is simply μ . As shown previously, the model order is constrained, on one hand, by the length of the data sequence $2n + \mu \ll N$. On the other hand, we have that $2n + \mu$

FIGURE 1. Sketch of the overlearning and bias error contribution to the total estimation error, as a function of the model order.

(and in particular μ since only a FIR is kept from the identification) has to be large with respect to the order of the model that describes the dynamics between the input and the output. A model order has to be chosen to balance these two criteria. Figure 1 graphically illustrates this balance that has to be struck. The bias error is related to an under-modelling of the dynamics, while the variance error is caused by a data-sequence which is too small compared to the model order. An *adequate* model order can be found by various means. The very common Akaike criterion is chosen for our work (see Akaike 1974). For model orders higher than Akaike's criterion, see 2.16, the model error is assumed to be mostly due to variance error; for model orders below Akaike's value, the model error is mostly due to bias error. In our case, the Akaike criterion reads

$$\text{AIC} = \log(J(W)) + \frac{2}{N} \text{card}(W). \quad (2.16)$$

This value can be computed *a posteriori*, once a model has been determined. The optimal model according to Akaike has a minimal AIC-value. The criterion contains two terms. The first term $\log(J(W))$ characterizes the residual minimization error, which is meant to represent the bias error of the identified model. Indeed, if the model order is sufficiently high, the problem becomes over-parameterized and $J(W)$ consequently tends to zero. However, if the model order is rather low, the problem is over-constrained and $J(W)$ may not vanish. The second term in (2.16) denotes an index that is correlated to the variance error. It increases linearly with the number of parameters in the model and penalizes over-parameterization. For our ARMarkov-model, the cardinality $\text{card}(W)$ is the number of parameters $2n + \mu$. The model order that minimizes AIC is taken as the optimal order for the identification procedure.

The uncertainty propagation developed later allows us to estimate the variance error; the bias error, however, is far harder to estimate, particularly, when the noise-to-signal ratio is high. In order to take advantage of the variance error estimation, it is essential to choose a model order that is sufficiently high. What constitutes a sufficiently high model order is difficult to define theoretically based on only the data sequence. For the remainder of the article, we base the model order on the minimal value of AIC given in (2.16).

2.3. From identified system to controller design

Once a model of appropriate order has been identified, a control strategy can be defined. Among the various choices to manipulate the flow, we will concentrate on two of the most common approaches: simple feedback control and simple feed-forward control. Both

FIGURE 2. Feed-back (left) and feed-forward (right) control layout. G_i are transfer functions inherent to the system, K and C are the transfer functions of the respective controllers. The respective physical systems are indicated in shaded boxes.

strategies are outlined in figure 2 in the form of a block diagram; they cover the most widely studied structures to control oscillatory and convectively dominated fluid flows.

In these configurations, y represents the signal from the objective sensor which enters a user-specified objective function, and u is the control variable, i.e., the signal passed to the actuator. In the feed-forward configuration, an additional sensor is present, which provides information about incoming disturbances and acts as a proxy for the (upstream) disturbance environment. In either configuration, G_i stands for a transfer function describing the fluid behavior between input and output signals; the transfer functions of the respective controllers are denoted by K and C , respectively. For the feedback setup, we also account for environmental noise sources, indicated by u' and y' . Before describing performance and stability criteria, we briefly outline common design algorithms for the two control configurations.

2.3.1. Feedback controllers

One of the most commonly applied strategy for feedback control is the infinite-time-horizon LQG/LQR control. After the identified system has been converted to a state-space representation, for example, by using the Eigenvalue Realization Algorithm (ERA; Juang & Pappa 1985), a Kalman filter (for the optimal state-estimation from measurements) and a proportional controller (which minimizes the control objective) can be designed. A large body of literature gives details of this design process; a data-based feedback approach applied to a fluid system can be found, e.g., in Illingworth *et al.* (2011).

Regardless of the details of the designed controller, transfer functions of the feedback-controlled system can be expressed explicitly. They will be referred to as the closed-loop transfer function (CLTF) throughout this paper. The CLTF describing the influence of the noise signal u' on the output y reads

$$T_{CL} = \frac{G_0}{1 + G_0 K}, \quad (2.17)$$

while the closed-loop transfer function linking the noise signal y' to the same output is given by

$$T'_{CL} = \frac{G_0 K}{1 + G_0 K}. \quad (2.18)$$

2.3.2. Feed-forward controllers

This type of control is commonly applied to flows with a strongly convective behavior, where disturbances originating upstream are to be compensated. In this setup, an upstream sensor detects the incoming disturbances, after which an actuator counteracts

them to create a nearly disturbance-free environment farther downstream (at the location of the objective sensor). General algorithms to design such controllers fall within the category of Model Predictive Controllers (MPC). Following the diagram in figure 2(b), the mapping between the measured incoming perturbations s and the output (objective) sensor y is given by the transfer function G_1 . An equivalent link between the actuator signal u and the same output sensor y can be established and described by the transfer function G_0 . The goal of the control design is then to construct a controller transfer function C such that the signal passing through C and G_0 destructively interferes with the signal passing through G_1 . It is straightforward to show that $C = -G_0^{-1}G_1$ provides a control law that accomplishes this task. As before, the transfer function of a system controlled by a feed-forward controller (from the upstream to the downstream sensor) can be stated explicitly. We will refer to it as the controlled-system transfer function (CSTF), given by

$$T_{CS} = G_1 + G_0 C. \quad (2.19)$$

2.4. From controller design to performance and stability: Nyquist and Bode plot analysis

The two transfer functions can be used to determine performance and stability measures. However, one has to keep in mind that the true transfer functions are not known; only their identified variants are available. To formally differentiate the exact and identified transfer functions, we introduce G_i for the exact (but experimentally inaccessible) transfer function and $\hat{G}_i$ for the nominal (identified) transfer function. Differences between these two transfer functions can be traced back to uncertainties or noise in the processed data.

For performance and stability studies, a simple substitution of G_i by $\hat{G}_i$ in (2.17) and (2.19) and a small-difference expansion can be applied for a first estimate of the influences of data corruption. In some high noise-to-signal cases, however, a different approach, involving a better approximation of the identification error, is called for. In the following section, we give a brief summary of stability criteria for feedback (the Nyquist criterion) and feed-forward controller. Only stability issues will be dealt with in this article; uncertainty propagation, as introduced here, however is not limited to this output criterion.

2.4.1. The Nyquist stability criterion for feed-back controllers

Considering the expression for the $CLTF$ and $CLTF'$ in (2.17) and (2.18), the closed-loop transfer functions are singular when $G_0 K = -1$. This singularity is linked to the instability of the controlled system. The Nyquist plot is a representation of the open-loop transfer function $G_0 K(OLTF)$ as a parameterized curve (by frequency) in the complex plane. The phase and gain margins defined by the Nyquist plot are measures that quantify the distance of the open-loop transfer function $G_0 K$ to the point -1 in the complex plane. The phase margin is the maximally admissible phase variation of the system before stability is lost; the gain margin is the maximally admissible gain variation for the system to lose stability. The Nyquist curve can be recovered from the discrete-time transfer function (a function of z) by a transformation to a continuous-time transfer function (a function of the frequency ω) via $z = e^{i\omega T_e}$, where T_e stands for the sampling time step of the data sequence.

Figure 3 shows an example of a Nyquist plot. This figure gives a graphical definition of the phase and gain margins, as well as a potential reduction in the margins due to general uncertainties. For small noise-to-signal ratio the phase and gain margins can be satisfactorily estimated from the nominal system. As soon as uncertainties become more prevalent, the stability margins computed from the nominal system increasingly differ

FIGURE 3. Nyquist plot of the *OLTF*, showing phase and gain margins, based on the nominal system (left) and the nominal system with uncertainty bounds (right).

FIGURE 4. Bode diagram of the uncontrolled (thin black) and controlled (thick black) transfer function, showing H_∞ -based performance of nominal system (left) and the nominal system with uncertainty bounds (right).

from the exact margins. In this latter case, uncertainty has to be directly taken into account to properly correct the margins.

2.4.2. Performance analysis for feed-forward disturbance rejection controllers

For feed-forward control configurations and strictly convective systems (*i.e.*, with no feedback from the downstream input u to the upstream sensor s), the controller cannot be unstable. In this case, performance is of principal concern and constitutes the criterion for our analysis of uncertainty propagation. Performance will be defined using the maximum value of the *CSTF* (*i.e.*, its H_∞ norm). A controller is deemed effective if the maximum value of the transfer function without control is larger than the maximum value of the *CSTF*. Figure 4 provides a sketch of this criterion. In this figure, the uncontrolled and the controlled transfer function of the system are plotted, and the performance measure of the controller is evaluated. Similar to the feedback configuration, uncertainty bounds about the nominal transfer function may yield a pronounced reduction of this nominal performance.

3. Uncertainty propagation for the ARMarkov/LS-identification process

We proceed by developing procedures to estimate uncertainty bounds in the identified system stemming from uncertainty in the processed data. In our case, we assume that the standard deviation of the data is known. First, the uncertainty propagation is demon-

strated for the ARMarkov/LS identification algorithm, where the impact on the model parameters (Markov parameters and auto-regressive parameters) is quantified. This is followed by establishing a link between the uncertainty in the Markov parameter and the resulting uncertainty bounds in the Bode and Nyquist diagrams. As a validation of this established procedure, a Monte-Carlo variance estimation is then used, on a simple test case, to corroborate the uncertainty propagation results by alternative means; since this validation step is advisable, but incidental to our development of a step-by-step procedure, we relegate this study to the appendix.

3.1. Variance error: linear perturbation analysis of the least-squares algorithm

Contrary to Monte-Carlo techniques, we seek an explicit expression linking statistical information (such as the standard deviation) of the input data to an equivalent statistical measure of the Markov parameters. The uncertainty in the data is assumed to be additive; multiplicative uncertainty propagation analyses can be found in Skogestad & Postlethwaite (2001), but will not be considered here. In addition, we restrict ourselves to sufficiently small measurement uncertainty in order to justify a first-order perturbation approach. The original data sequence, described by the vector $\mathbf{Y}$, is perturbed as follows

$$\tilde{\mathbf{Y}} = \mathbf{Y} + \delta\mathbf{Y}. \quad (3.1)$$

The influence of the perturbation $\delta\mathbf{Y}$ on the identified parameters (contained in $\mathbf{W}$) can be quantified using (2.13). We note that, since Φ contains past measurements, the size N of the total data sequence differs from the number of equation $N - \mu - n + 1$. For this reason, two notations must be put forth: the vector of output data $\mathbf{Y}$ of size N , and the solution $\mathbf{Y}_t$ of the least-squares problem of size $N - \mu - n + 1$

$$(\mathbf{W} + \delta\mathbf{W}) = (\Phi + \delta\Phi)^\dagger \cdot (\mathbf{Y}_t + \delta\mathbf{Y}_t). \quad (3.2)$$

The resulting perturbations $\delta\mathbf{W}$ of the model parameters $\mathbf{W}$ is sought as a function of the perturbation $\delta\mathbf{Y}$ in the data $\mathbf{Y}$. Under the previously mentioned assumption of small perturbations $\delta\mathbf{Y}$, we linearize the above expression and derive a first-order perturbation solution for $\delta\mathbf{W}$. This step is equivalent to linearizing the pseudo-inverse term $(\Phi + \delta\Phi)^\dagger$, a complex problem that has been the object of many past studies (see Wedin 1973; Stewart 1977, 1990). Before proceeding, we have to state the following underlying hypothesis and assumption: $\text{rank}(\Phi) = \text{rank}(\tilde{\Phi})$ which states that the rank of Φ is not affected by the additive perturbation $\delta\Phi$. This statement is true for sufficiently small $\delta\mathbf{Y}$; in fact, the rank preservation defines the size of the admissible perturbations $\delta\mathbf{Y}$.

Under this assumption, we can give an explicit expression for the model parameter perturbations $\delta\mathbf{W}$ (see Stewart 1977)

$$\delta\mathbf{W} \approx \Phi^\dagger \delta\mathbf{Y}_t + (-\Phi^\dagger \mathbf{P}_\Phi \delta\Phi \mathbf{R}_\Phi \Phi^\dagger + (\Phi^T \Phi)^\dagger \mathbf{R}_\Phi \delta\Phi^T \mathbf{P}_\Phi^\perp - \mathbf{R}_\Phi^\perp \delta\Phi^T \mathbf{P}_\Phi (\Phi \Phi^T)^\dagger) \mathbf{Y}_t, \quad (3.3)$$

where

$$\mathbf{P}_\Phi \equiv \Phi \Phi^\dagger, \quad \mathbf{R}_\Phi \equiv \Phi^\dagger \Phi, \quad (3.4a)$$

$$\mathbf{P}_\Phi^\perp \equiv \mathbf{I} - \mathbf{P}_\Phi, \quad \mathbf{R}_\Phi^\perp \equiv \mathbf{I} - \mathbf{R}_\Phi. \quad (3.4b)$$

The matrix $\delta\Phi$ contains perturbations of the data-sequence. By definition, it can be directly expressed in terms of $\delta y(k)$ for $k \in [1, N]$ according to

$$\delta\Phi = \begin{pmatrix} \delta y(n) & \delta y(n-1) & \dots & \delta y(1) & 0 & \dots & 0 \\ \delta y(n+1) & \delta y(n) & \dots & \delta y(2) & 0 & \dots & 0 \\ \vdots & \vdots & & \vdots & \vdots & \ddots & \vdots \\ \delta y(N) & \delta y(N-1) & \dots & \delta y(N-n+1) & 0 & \dots & 0 \end{pmatrix} \quad (3.5)$$

or, in a more compact form,

$$\delta\Phi = \sum_{k=1}^N \mathbf{E}(k) \delta y(k) \quad (3.6)$$

where we have introduced the operator $\mathbf{E}(k)_{i,j}$ as

$$\mathbf{E}(k)_{i,j} = \begin{cases} 1 & \text{if } i - j + n = k \text{ and } i < n, \\ 0 & \text{elsewhere.} \end{cases} \quad (3.7)$$

With this definition, we can reformulate the above relation between the data perturbations and the model parameter perturbations and state it in the form

$$\delta\mathbf{W} \approx \Phi^\dagger \delta\mathbf{Y}_t + \sum_{k=1}^N \left(-\Phi^\dagger \mathbf{P}_\Phi \mathbf{E}(k) \mathbf{R}_\Phi \Phi^\dagger + (\Phi^T \Phi)^\dagger \mathbf{R}_\Phi \mathbf{E}(k)^T \mathbf{P}_\Phi^\perp - \mathbf{R}_\Phi^\perp \mathbf{E}(k)^T \mathbf{P}_\Phi (\Phi \Phi^T)^\dagger \right) \mathbf{Y}_t \delta y(k). \quad (3.8)$$

Finally, this expression is equivalent to

$$\delta\mathbf{W} = \mathcal{L} \delta\mathbf{Y} \quad (3.9)$$

where $\mathcal{L}$ can be interpreted as the Jacobian of $\mathbf{W}$ with respect to $\mathbf{Y}$. Consequently, the gradient of each component of $\mathbf{W}$ with respect to a specific perturbation in the processed data can be extracted from $\mathcal{L}$. We recall that only the Markov parameters $\mathbf{H}_i$ are relevant for the representation of the system-identified model. With the definition of $\mathbf{W}$, the propagation of data-uncertainties into each Markov parameter can be found from (3.9). If we introduce the notation $\mathcal{L}_i$ as the i^{th} row of the Jacobian $\mathcal{L}$, we obtain

$$\delta\mathbf{H}_i = \mathcal{L}_{i+n} \delta\mathbf{Y}, \quad i = 1, \dots, \mu. \quad (3.10)$$

With the above link between the data perturbations and Markov parameter perturbations, we can now establish a mapping between statistical properties of the two perturbations. To this end, let $\sigma_{\delta y}$ and $\sigma_{\delta\mathbf{H}_i}$ denote, respectively, the standard deviation of the measurement noise and of the i^{th} Markov parameter. Further introducing the noise standard deviation $\delta\mathbf{Y}^T \delta\mathbf{Y} = N\sigma_{\delta y}^2$, we can state

$$\sigma_{\mathbf{H}_i} = \sigma_{\delta y} \sqrt{\mathcal{L}_{i+n} \mathcal{L}_{i+n}^T}. \quad (3.11)$$

This final expression (3.11) describes the first-order uncertainty mapping (in terms of the standard deviation) from the output data sequence to the identified Markov parameters; given the noise standard deviation, it is now possible to determine uncertainty bounds for each Markov parameter. These bounds are associated with statistical probabilities: if the measurement noise is Gaussian, the i^{th} Markov parameter falls within the range $\mathbf{H}_i \pm \sigma_{\mathbf{H}_i}$ with a 68.2% probability or is contained within $\mathbf{H}_i \pm 2\sigma_{\mathbf{H}_i}$ with a 95% probability. However, evaluating the 95% probability range of a specific Markov parameter is not an effective way of probing the potential impact of data uncertainty on the controlled-system behavior. Rather, a direct influence on stability or performance criteria is sought. As stated in section § 2.4, we will limit our stability and performance assessment to criteria that can be straightforwardly extracted from Nyquist or Bode plots.

Two approaches to extend the uncertainty analysis to apply to stability and performance measures come to mind. First, the numerical procedures to compute the criteria and corresponding margins can be linearized about a nominal set of Markov parameters, after which the Jacobian of these criteria/margins with respect to data uncertainty can be extracted. Such a linearization, however, is rather cumbersome owing to the complex steps in computing the criteria and margins; for instance, the stability phase margin in the Nyquist diagram of a feedback controller requires to (i) compute a transfer function, (ii) find the frequency for which the gain is one, and (iii) determine the minimal phase between this frequency and the singularity at $z = -1$ in the complex plane. Each of these three steps needs to be linearized to arrive at sensitivity measures. An alternative, and more attractive, technique to extend the uncertainty analysis to stability and performance measures is based on a Monte-Carlo approach. We recall that the Monte-Carlo method has been dismissed as an option for determining the uncertainty propagation from measurement errors to Markov parameters. Our reasoning came from the prohibitively large dimensionality of the space that defines the measurement uncertainty, and ultimately led us to the linearization approach. For the sensitivity measure of stability and performance quantities, however, the situation is reversed: the number of Markov parameters μ is substantially smaller than the number N of measurement points (for example, $N \approx 10^4$ whereas $\mu \approx 10^2$), and Monte-Carlo techniques thus become a viable option. In short, once the uncertainty of the identified Markov parameters is known (using linearization of the least squares identification), a more appealing Monte-Carlo procedure may be used for the final step of the uncertainty analysis — from Markov-parameter perturbations to performance/stability margins. The uncertainty regions around the nominal Nyquist and Bode diagram are thus computed using a large number of possible systems taken within the uncertainty bounds of the identified Markov parameters (see equation (3.11)).

In summary, for a given set of perturbed data, a Nyquist or Bode plot including uncertainty bounds may be computed as follows: (i) solve the nominal problem for W , using the pseudo-inverse of Φ , according to (2.13); (ii) compute the Jacobian Matrix $\mathcal{L}$ defined in (3.9) using the nominal solution; (iii) compute the standard deviation of each Markov parameter based on (3.11); (iv) generate a large number (order μ) of transfer functions using Markov parameters that are given by their mean (nominal value) and standard deviation (from the above uncertainty propagation); (v) compute the standard deviation of the Nyquist or Bode plots, or any other stability or performance criterion, from this set of transfer functions. In the following section we apply the above procedure to several test cases of controllers.

4. Application to a test flow

We consider a linear numerical simulation of flow over an idealized airfoil followed by an infinite plate. The airfoil consists of a circular body of radius R and two straight segments joining at the trailing edge. The Reynolds number based on R is $Re = 400$, the radius $R = 0.5$ and the chord length is 4.6 non-dimensional units; see figure 5 for a sketch of the flow configuration. With a unit inflow velocity, the viscosity is chosen to correspond to the inverse Reynolds number $\nu = 1/Re$. The flow domain is meshed by a two-dimensional unstructured grid of about $5 \cdot 10^5$ nodes. First, a stable base flow is computed using a Newton iterative solver. Then, equations for the temporal evolution of perturbations (u, v, p) around this base flow are formulated and spatially discretized using finite elements (in our case, P_2 - P_1 Taylor-Hood elements). The pressure field is computed using the Uzawa algorithm with a Cahouet-Chabart preconditioner (see Glowinski 2003). The time discretization is semi-implicit based on a second-order backward-differentiation

FIGURE 5. Numerical domain and boundary condition for the case of flow over an idealized airfoil.

scheme. We choose a time step of $\Delta t = 0.003$ for the simulations. Data sequences generated by the simulations are extracted with a time-step of $dt = 0.075$, before being subjected to the identification algorithms. The length of the sampled data is $N = 1500$, and the entire measurement sequence is used in the identification algorithms. Two simulations are performed: the first contains an upstream source of noise (one radius R upstream of the leading edge) that creates fluctuations in the flow field which are detected by both sensors; in the second simulation, a broad-band pseudo-random binary signal (PRBS) is applied to the input which mostly affects the downstream sensor. Artificial measurement perturbations are added to the downstream sensor, using a white Gaussian noise with the same variance as the noise-free signal variance (*i.e.*, we consider a 100% noise contamination). All identified nominal transfer functions will be found using the ARMarkov identification algorithm with the set of parameters $\mu = 200$, $n = 20$ and $N = 1500$. Based on the given noise standard deviation, the standard deviation of each Markov parameter is estimated using the uncertainty propagation algorithm given by (3.11). Finally, exact transfer functions are also identified from longer noise-free data signals (with $N = 4000$). These latter signals are assumed unobtainable in realistic experiments; they are computed here solely for a performance evaluation of the uncertainty propagation algorithm.

With the nominal transfer function and the different controller transfer functions known, it is then possible to estimate the performance and stability of a given controlled system. The next subsections focus on two control setups: a feedback and a feed-forward configuration. It will be shown that the exact performance and stability is quite different from the nominal values, and that this difference is well predicted by the uncertainty propagation technique.

4.1. Feedback control

We first consider a feedback configuration for flow over the idealized airfoil. The developed framework applies to the block diagram shown in figure 2(a) where, in the present case, y denotes the signal from the downstream sensor and u stands for the upstream control input. From the realistic (*i.e.*, noise-contaminated) data sequence, the nominal transfer function (Markov parameters) is identified using the ARMarkov/LS identification algorithm. The number of identified Markov parameters is set to $\mu = 200$, which is about 1.4 times the AIC value of $\mu = 144$. The nominal system together with the noise standard deviation then provides an estimate of the standard deviation of the identified Markov parameters. This latter standard deviation can be interpreted as uncertainty bands about the nominal transfer function.

For demonstration purposes, we assume a proportional feedback controller with $K = 0.025$. The stability of the closed-loop system is determined by the distance of the open-loop transfer function $G_0 K$ to the point -1 ; see (2.17). Figures 6(a) and (b) show the Nyquist plots of the exact OLTF, the nominal OLTF and the uncertainty bounds associated with twice the standard deviation at each frequency. These bounds correspond to

FIGURE 6. Nyquist plot of the Open Loop Transfer Function (OLTF): (red) exact, (black) nominal value; the 95%-likelihood bounds around the nominal value are given by dashed-blue lines. (b) Magnified detail of the OLTF in (a) near the point $z = -1$ with arrows showing the nominal and real gain margins. The dashed black line indicates the unit circle.

a confidence interval of 95%, i.e., in only 5% of cases does the real OLTF fall outside these bounds. Furthermore, the nominal transfer function of the controlled system shows a gain margin of $\text{GM}^+ = 0.033\text{dB}$ which overestimates the real gain margin by more than 40% ($\text{GM}^+ = 0.023\text{dB}$). Our uncertainty propagation algorithm gives estimates for the gain margin of more than $\text{GM}^+ = 0.017\text{dB}$ with a probability of 95%, and more than $\text{GM}^+ = 0.025\text{dB}$ with a probability of 68.2%. According to the same algorithm, the standard deviation of the gain margin is about $\sigma_{\text{GM}^+} = 0.008\text{dB}$. In contrast, the singularity at -1 is nearly four standard deviations away from the nominal transfer function, which — according to the gain margin criterion and under the assumption of Gaussian noise — suggests that in only 0.1% of all cases should we expect an unstable feedback-controlled system. A similar comparison may be performed using the phase margin: the nominal margin is $\text{PM} = 29^\circ$, the exact phase margin is $\text{PM} = 21^\circ$, while the 95%-likelihood margin is determined as $\text{PM} = 13^\circ$.

In this feedback control example, compared to the nominal transfer function, the real transfer function tends to overestimate the stability margins of the closed-loop system. The uncertainty propagation technique allows a quantitative estimation of the error bounds which results in a more realistic estimation of these margins.

4.2. Feed-forward control

In feed-forward control applications, the control performance is often measured by the maximum magnitude of the controlled system transfer function (CSTF). In this case, the input signal comes from the upstream sensor (see figure 5). As before, this controlled system transfer function can be estimated with the nominal identifications and compared to the real transfer function. Figures 7(a) and (b) show the transfer function of the exact system without control, the nominal controlled system and the exact controlled system. This time, the performance of the controller seems to be positive (note the reduction of the maximal amplitude) with the nominal estimation. However, a closer look reveals that the real system behaves worse with control than without. This can be predicted using the 95%-uncertainty bounds which show the probable lack of performance of the controlled system.

FIGURE 7. Bode diagram of the uncontrolled system (black line), the nominal CSTF (black thick line), and the exact CSTF (red); the error bounds around the nominal CSTF are shown by black mix-dashed lines. The maximum amplitude of the uncontrolled system is represented by a dashed horizontal line. (b) Magnified view of (a) for a limited frequency range.

5. Conclusions

The identification error due to measurement uncertainty can have an important effect on the stability margins and performance bounds of any data-based controller. In this study, an uncertainty propagation technique has been developed and applied to two types of control architectures: feedback and feed-forward control. In both cases, the nominal prediction overestimate either the controller's performance or stability margins. When input-data uncertainty is taken into account, more accurate predictions can be made. Even though uncertainty propagation may be treated via Monte-Carlo analysis, the related computational costs are often prohibitive. In contrast, a linearization of the identification algorithm provides statistical information about the identified transfer function, requiring only one single experiment and thus overcoming the previous computational bottleneck. Estimating *a priori* the performance and stability characteristics of a given controller, using the data-sequences from which the controller has been designed, may lead to a better design of control strategies. In fact, controllers are commonly built to be optimal in the nominal sense. Being able to give a robust definition of optimality with respect to uncertainty should allow the construction of control setups that are more relevant for implementation in experiments or more suited for the control of flows under realistic conditions.

Appendix A. Transfer functions for linear time-invariant systems

Three different models have been introduced in section § 2.1. For completeness sake, we present the transfer functions of these models which can be obtained by taking the z -transform of the equivalent discrete-time models.

For the finite-impulse response (FIR) model we obtain the transfer function

$$G(z) = H_0 + H_1 z^{-1} + \dots + H_{\mu-1} z^{1-\mu}. \quad (\text{A } 1)$$

with H_i as the Markov parameters (discrete impulse response). The transfer function is simply a sum of monomials in z^{-1} . Following the same procedure, the more complicated

auto-regressive moving average (ARMA) model yields the transfer function

$$G(z) = \frac{M_0 + M_1 z^{-1} + \dots + M_n z^{-n}}{1 + N_1 z^{-1} + \dots + N_n z^{-n}} \quad (\text{A } 2)$$

which represents a rational function in z^{-1} to approximate the transfer function of the identified system. The third and final model, the ARMarkov model, has the transfer function

$$G(z) = \frac{H_0 + H_1 z^{-1} + \dots + H_{\mu-1} z^{-(\mu-1)} + z^{-\mu}(Q_0 + Q_1 z^{-1} + \dots + Q_n z^{-n})}{1 + z^{-\mu}(N_1 z^{-1} + \dots + N_n z^{-n})} \quad (\text{A } 3)$$

which also represent a rational approximation of the system response but, contrary to the previous ARMA model, contains the first μ Markov parameters H_i explicitly.

Appendix B. Validation using Monte-Carlo simulation

We will validate the perturbation framework introduced in the main text using Monte-Carlo simulations. In particular, we wish to assess the dependence of the perturbative approach on the signal-to-noise ratio of the processed data. To this end, we introduce the parameter γ defined as $\gamma = \sigma_{\delta y} / \sigma_y$, measuring the standard deviation of the perturbations with respect to the standard deviation of the unperturbed data. For efficiency reasons, we choose as our test case a system that can be solved quickly, yet still has characteristics of a full-scale fluid system. In particular, the chosen system should produce data-sequences reminiscent of many fluid systems: with a range of certain frequencies amplified by the flow, while other frequencies damped, and with a delay between input and output signals mimicking advection.

The selected test case consists of incompressible flow around a cylinder ($Re = 40$), modeled by the linear complex Ginzburg-Landau equation. An actuator is placed about half a radius upstream of the cylinder, and the sensor is located in the stable wake; both impose or provide signals of the normal-velocity component. The linear Ginzburg-Landau model equation is solved numerically using finite differences on a one-dimensional equispaced mesh of $N = 100$ grid points. The relatively small dimensionality of the system facilitates the convergence of the Monte-Carlo variance estimation. The flow behaves as a filter with delay, and the power spectral density of the output signal (given white-noise input) is plotted in figure 8 (solid line); it shows amplification of lower frequencies (around 25 mHz) and a strong damping of higher frequencies. The input sequence has been generated with a Pseudo-Random Binary Signal (PRBS) algorithm. A total of 500 noise-free numerical experiments have been performed, resulting in 500 independent noise-free input-output data sequences with each sequence containing 1000 measurement-points sampled at 1 Hz (i.e., about 50 times the characteristic time scale of the system). The length of each sequence represents 25 characteristic time units. This length and the sampling frequency are adequate to accurately identify the system behavior (see section 2.2).

After establishing the base-line data-sequences, we add noise to each of the 500 experiments. In general, three different approaches can be distinguished. The added noise could be (i) broadband and affect all frequencies nearly equally. Alternatively, it could be strongly colored with (ii) higher amplitudes near the system's natural frequency or (iii) with higher amplitudes at higher frequencies that do not correspond to physically observed frequencies. Often, the system's characteristic frequency can be estimated, which allows the application of low-pass filters to eliminate the noise for the third case. In the

FIGURE 8. Power spectral density of the different measurement disturbances: crosses denote the white noise, circles show the colored noise 1, the dashed-line displays the colored noise 2. The spectrum of the noise-free output signal is represented by the solid line.

first two cases, low-pass filtering will not succeed in eliminating the noise components in the data. For this reason, we will focus on these cases.

Three different measurement contaminations will be considered: white noise and two colored noise distributions with a pronounced amplitude near the system's characteristic frequencies. Their power spectra are presented in figure 8 together with the output power spectrum. These noise spectra cannot be simply filtered and are likely to influence the value of the identified Markov parameters. Their noise-to-signal ratio γ is set by choosing the noise amplitude. For each of the three noise spectra and for every considered noise-to-signal ratio, we compare the statistical information estimated by the Monte-Carlo approach to the same information computed by the uncertainty algorithm of the main text. The mean standard deviation of the identified Markov parameter ($\text{mean}(\sigma_H)$) is the objective for this test case; it has to be compared to the average of the Markov parameter value which is one. If $\text{mean}(\sigma_H) = 10^{-2}$, the variance error is estimated to be on average one percent for each Markov parameter.

First, 500 noisy data-sequences are used to estimate the standard deviation of the identified Markov parameters (the Monte-Carlo approach). Then, one single input-output data-sequence and the noise standard deviation are used to estimate the standard deviation of the identified Markov parameters (using the uncertainty propagation approach). For the Monte-Carlo estimation, each of the 500 perturbed input-output data-sequences is used in the ARMarkov/LS identification algorithm, yielding the corresponding Markov parameters; from these 500 sets of Markov parameters, their means and standard deviations can easily be determined. For the uncertainty propagation, one arbitrarily perturbed data-sequence is taken as input to the algorithm of section 3. Equation (3.11) produces the standard deviation of the Markov parameters based on the noise standard deviation, from which the mean can be computed. The parameters for the different algorithms are $N = 1000$, $\mu = 400$, $n = 40$, and ϵ is set to machine precision. The corresponding

FIGURE 9. Monte-Carlo (blue dots) and uncertainty propagation (red squares) estimates of the standard deviation of the identified Markov parameters as a function of the noise-to-signal ratio γ . (left) measurement contamination by white noise; (middle) measurement contamination by low-pass filtered noise 1; (right) measurement contamination by low-pass filtered noise 2.

AIC is not given, since its value varies with each noise-to-signal ratio and each color of noise. Figure 9 shows the results of the standard deviation estimates for each algorithm (Monte-Carlo and uncertainty propagation) and for each noise-spectrum/noise-to-signal ratio.

As can be deduced from figure 9, the three different noise spectra (measurement contaminations) affect the standard deviation of the Markov parameters in a similar manner. Independent of the noise spectrum, the Monte-Carlo and uncertainty propagation approaches give identical estimates for high noise-to-signal ratios, thus validating the uncertainty propagation algorithm for sufficiently high values of γ . According to these experiments, accurate estimates of the standard deviation of the Markov parameters can be expected for noise-to-signal ratios γ between 10^{-5} and 2 (very noisy signal). For low values of γ ($\ll 10^{-5}$), two reasons may explain the discrepancy between the Monte-Carlo results and the uncertainty propagation. First, the standard deviation may be influenced by round-off errors which become important at 10^{-8} due to the square root dependence of the standard deviation. Secondly, with only 500 samples available, the Monte-Carlo algorithm may only be converged up to 10^{-6} . In any event, realistic data-sequences taken from fluid systems are rarely contaminated by noise of less than 0.001%.

This simple test case illustrates that uncertainty propagation provides accurate and valuable estimates of the Markov-parameter variance error for realistic noise-to-signal ratios.

REFERENCES

- AKAIKE, H. 1974 Fitting autoregressive models for prediction. *IEEE Trans. Autom. Contr.* **19**, 716–723.
- AKERS, J.C. & BERNSTEIN, D.S. 1997 ARMarkov least-squares identification. In *Proc. Amer. Contr. Conf.* Albuquerque, NM.
- BRIGHENTI, C., WAHLBERG, B. & ROJAS, C.R. 2009 Input design using Markov chains for system identification. In *Joint 48th IEEE Conf. Dec. and Contr. and 28th Chin. Contr. Conf.*, pp. 1557–1562. Shanghai, P.R. China.
- FLEDDERJOHN, M.S., HOLZEL, M.S., PALANTHANDALAM-MADAPUSI, H.J., FUENTES, R.J. &

- BERNSTEIN, D.S. 2010 A comparison of least squares algorithm for estimating Markov parameters. In *Amer. Control Conf. (ACC)*, pp. 3735–3740. Baltimore, MD.
- FLEMING, J. 2011 Generalized Tikhonov regularization: Basic theory and comprehensive results on convergence rates. PhD thesis, Techn. Univ. Chemnitz.
- GERENCSE, L., HJALMARSSON, H. & MARTENSSON, J. 2009 Identification of ARX systems with non-stationary inputs – asymptotic analysis with application to adaptive input design. *Automatica* **45**, 623–633.
- GLOWINSKI, R. 2003 Finite element methods for incompressible viscous flow. In *Handbook of Numerical Analysis*, , vol. 9, pp. 3–1176. Elsevier.
- HERVÉ, A., SIPP, D., SCHMID, P.J. & SAMUELIDES, M. 2012 A physics-based approach to flow control using system identification. *J. Fluid Mech.* **702**, 26–58.
- HJALMARSSON, H. 2005 From experiment design to closed-loop control. *Automatica* **41**, 393–438.
- ILLINGWORTH, S.J., MORGANS, A.S. & ROWLEY, C.W. 2011 Feedback control of flow resonances using balanced reduced-order models. *J. Sound Vibr.* **330** (8), 1567–1581.
- JUANG, J.N. & PAPP, R.S. 1985 Eigensystem Realization Algorithm for modal parameter identification and model reduction. *J. Guid. Contr. Dyn.* **8** (5), 620–627.
- JUILLET, F., SCHMID, P.J. & HUERRE, P. 2013 Control of amplifier flows using subspace identification. *J. Fluid Mech.* **725**, 522–565.
- KAMRUNNAHAR, M., HUANG, B. & FISHER, D.G. 2000 Estimation of Markov parameters and time-delay/interactor matrix. *Chem. Eng. Sci.* **55** (17), 3353–3363.
- KATAYAMA, T. 2005 *Subspace Methods for System Identification*. Springer-Verlag.
- KIM, J. 2003 Control of turbulent boundary layers. *Phys. Fluids* **15** (5), 1093–1105.
- LEW, J.-S., JUANG, J.-N. & LONGMAN, R.W. 1993 Comparison of several system identification methods for flexible structures. *J. Sound Vibr.* **167** (3), 461–480.
- LJUNG, L. 1987 *System Identification: Theory for the User*. Prentice-Hall, Inc.
- LONGMAN, R.W., LEW, J.-S., TSENG, D.-H. & JUANG, J.-N. 1991 Variance and bias computation for improved modal identification using ERA/DC. *Amer. Control Conf.* pp. 3013–3018.
- MA, Z., AHUJA, S. & ROWLEY, C.W. 2011 Reduced order models for control of fluids using the Eigenvalue Realization Algorithm. *Theor. Comp. Fluid Dyn.* **25** (1), 233–247.
- MEHRA, R.K. 1974 Optimal inputs for linear system identification. *IEEE Trans. Autom. Contr.* **19** (3), 192–200.
- RISSANEN, J. 1983 A universal prior for integers and estimation by minimum description length. *The Annals of Stat.* **11** (2), 416–431.
- SKOGESTAD, S. & POSTLETHWAITE, I. 2001 *Multivariable Feedback Control – Analysis and Design*. John Wiley and Sons, Ltd.
- STEWART, G.W. 1977 On the perturbation of pseudo-inverses, projection and linear least squares problems. *SIAM Rev.* **19** (4), 634–662.
- STEWART, G.W. 1990 Perturbation theory and least squares with errors in the variables. *Contemp. Math.* **112** (4).
- VAN PELT, T. & BERNSTEIN, D.S. 1998 Least squares identification using μ -Markov parameterizations. In *Proc. 37th IEEE Conf. Dec. and Contr. 1998*, , vol. 1, pp. 618–619.
- WEDIN, P.A. 1973 Perturbation theory for pseudo-inverses. *BIT Num. Math.* **13** (2), 217–232.